

**Himachal Pradesh
Public Works Department**

No.PWU/CB/WA/B-6/2023-24-

1855-56

Dated:-

30-05-2023

To,

The Principal,
K.C Public School Pandoga
Tehsil Haroli Distt. Una

Subject: - Regarding issue of Building safety Certificate 2023-26.

Sir,

Enclosed please find herewith the building safety certificate for the year 2023 -2026 of K.C Public School Pandoga Tehsil Haroli Distt. Una for favour necessary action please.

DA/As above.

Executive Engineer,
Una Division, HP.PWD,
Una.


Copy to the Assistant Engineer, T/wala Sub-Division HP,PWD Haroli for information with reference to his office letter No.458 Dated 26.05.2023.


Executive Engineer,
Una Division, HP.PWD.,
Una.

Building safety Certificate

The School building of K.C. Public School Pandoga Tehsil Haroli Distt. Una inspected by the undersigned along with concerned Junior Engineer on dated 25.05.2023. It has been observed that no earth quake resistance provision has been adopted for this building and no structure drawing is approved by the competent Govt. certified Engineer which has been produced at the time of inspection and moreover no assistance was taken from Public Works Department for construction of the building. Hence the structure safety of this building cannot be assured specially from earthquake resistance point of view. This department will not be held responsible for any type of loss of life and property etc. If this structure falls under any circumstances. The year of construction of building is 2009 as certificate by the Pradhan Gram Panchyat Pandoga Tehsil Haroli Distt. Una (HP) However as per the visual inspection it has been observed that the existing building seems to be safe for running academic session 2023-26, as per guidelines issued by the Special Secretary (PW) to the Govt. of H.P notification No. PBW (B) (3) 95/2019 dated 13.04.2021. No Officer/ official of this department would attend any plea in any Hon'ble Court of law for any type of dispute and claim and loss.

This certificate for official use and not for legal purpose.


Assistant Engineer,
Tahliwala Sub-Division
HP: PWD Haroli.

ys 
Executive Engineer
Una Division (B&R)
H P.P W.D. Una (H.P.)